Page 1 of 16



# **Certificate of Analysis**

MRA Report #: M18-091T

Report Date: September 6, 2018

Report Type: EEStor, Inc. Samples Performance Testing

Prepared for: Mr. Ian Clifford

EEStor, Inc.

715 Discovery Boulevard #107

Cedar Park, TX 78613

P.O. No: 3158-00'18 (Sample #4)

# The following sample was submitted and identified on behalf of the client as:

Sample ID's: CS-18-13-4 – Densified ceramic disk, Customer ID# L-3H

Material types: Densified ceramic disk capacitor

Quantity: One per sample

Testing Period: August 21, 2018 – September 5, 2018

Objective: To independently illustrate the performance of EEStor materials across the

range of operating conditions

Page 2 of 16

Performed tests: **Test #1:** Capacitance & Dissipation Factor vs. Frequency (20Hz – 2MHz)

@1Vrms, RT, 0V dc-bias;

**Test #2:** Capacitance & Dissipation Factor vs. dc-bias (up to 1000V)

@1kHz, RT;

Test #3: Temperature Coefficient of Capacitance @ 1kHz,

-55°C – 200°C temperature range, 0V dc-bias;

Test #4: Temperature Coefficient of Capacitance at dc-bias @ 1kHz,

-55°C – 200°C temperature range, 300V dc-bias;

Test #5: Insulation Resistance @1000V, RT and 125°C;

**Test #6:** HALT @1000V, 180°C, 100h;

Test #7: Dielectric Breakdown Strength both at AC (up to 5000Vac) and

DC (up to 6000Cdc) voltages;

**Test #8:** Cross-section and optical/SEM microstructure evaluation.

Summary: The results are given on the following pages as tables and plots for

information only.

# **Customer Samples Dimensions**

Sample ID#	Customer ID#	Electrode dimensions (diameter or length and width), mm	Sample thickness, mm	Electrodes area, mm <sup>2</sup>
CS-18-13-4	#L-3H	5.69	0.55	25.42

Used equipment: Precision micrometer, 210-A.

Measured uncertainty: ±0.001mm.

Room temperature: 19.2°C. Relative humidity: 49.2%.

Page 3 of 16

# **Test Results:**

Test #1: Capacitance & Dissipation Factor vs. Frequency (20Hz – 2MHz)

(@ 1Vrms, 0V dc-bias, room temperature)


Freq., Hz	CS-18-13-4 (#L-3H)	
	Cap, nF	DF, %
20	3.386	2.239
100	3.308	2.052
1,000	3.212	2.065
10,000	3.112	2.412
100,000	2.996	3.252
1,000,000	2.842	6.608
2,000,000	2.777	9.423

Used equipment: Keysight E4980A precision LCR meter.

Measured uncertainty: C, DF  $\pm 0.1\%$ .

Room temperature: 19.2°C. Relative humidity: 49.2%.

Freq., Hz	CS-18-13-4 (#L-3H)	
17)	Estimated Dielectric Constant	
20	8218	
100	8029	
1,000	7796	
10,000	7553	
100,000	7271	
1,000,000	6898	
2,000,000	6740	



15 Print Works Drive Adams, MA 01220

Page 4 of 16

Test #2: Capacitance & Dissipation Factor vs. dc-bias (up to 1000V)

(@ 1 kHz, room temperature)

do bios V	CS-18-13	3-4 (#L-3H)
dc-bias, V	Cap, nF	DF, %
0	3.089	2.197
25	3.231	2.996
50	3.251	3.091
100	3.154	2.938
200	2.849	2.584
300	2.533	2.281
400	2.258	2.071
500	2.017	1.901
600	1.808	1.762
700	1.630	1.652
800	1.475	1.565
900	1.340	1.467
1,000	1.226	1.408


Used equipment: Keysight E4980A precision LCR meter.

Measured uncertainty: C, DF  $\pm 0.1\%$ .

Room temperature: 19.2°C. Relative humidity: 49.2%.

do bios V	CS-18-13-4 (#L-3H)		
dc-bias, V	E, V/ μm	Cap, %	
0	0.000	100.000	
25	0.046	104.597	
50	0.092	105.244	
100	0.183	102.104	
200	0.366	92.230	
300	0.549	82.001	
400	0.732	73.098	
500	0.916	65.296	
600	1.099	58.530	
700	1.282	52.768	
800	1.465	47.750	
900	1.648	43.380	
1,000	1.831	39.689	

Page **5** of **16** 



Page 6 of 16

**Test #3: Temperature Coefficient of Capacitance** 


(@ 1 kHz, -55°C – 200°C temperature range, 0V dc-bias)

Temp.,	CS-18-13-4 (#L-3H)	
°C	Cap, %	DF, %
-55	-64.41	4.69
-45	-59.52	4.42
-35	-53.49	4.21
-25	-46.23	3.94
-15	-37.54	3.65
-5	-27.07	3.43
5	-15.42	3.12
15	-6.17	2.78
25	0.00	2.43
35	4.68	2.11
45	6.29	1.86
55	3.52	1.69
65	-3.52	1.49
75	-12.65	1.34
100	-38.60	0.98
125	-58.66	0.65
150	-71.24	0.39
175	-78.82	0.27
200	-83.57	0.26

Used equipment: HP 4278A Capacitance meter and Delta 9023 environmental chamber.

Measured uncertainty: C, DF  $\pm 0.25\%$ .

Room temperature: 19.2°C. Relative humidity: 49.2%.



15 Print Works Drive Adams, MA 01220

Page **7** of **16** 

**Test #4: Temperature Coefficient of Capacitance at dc-bias** 

(@ 1 kHz, -55°C – 200°C temperature range, 300V dc-bias)


Temp., °C	CS-18-13-4 (#L-3H)			
	0V dc-bias		300V dc-bias	
	Cap, %	<b>DF</b> , %	Cap, %	<b>DF</b> , %
-55	-65.44	4.35	-69.23	4.30
-45	-61.91	4.30	-65.16	4.04
-35	-55.98	4.06	-60.10	3.76
-25	-48.79	3.85	-54.19	3.44
-15	-39.63	3.62	-47.00	3.10
-5	-28.24	3.47	-38.63	2.78
5	-16.18	3.14	-31.53	2.35
15	-6.86	2.86	-25.82	2.50
25	0.00	2.48	-23.51	2.14
35	4.02	2.02	-22.87	1.09
45	4.28	1.68	-24.59	0.92
55	0.76	1.42	-27.47	0.75
65	-6.65	1.16	-31.61	0.61
75	-15.69	0.98	-36.22	0.51
85	-26.27	0.81	-41.68	0.43
95	-36.64	0.67	-47.48	0.37
105	-45.95	0.55	-53.19	0.33
115	-53.95	0.45	-58.64	0.29
125	-60.61	0.37	-63.54	0.26
135	-66.03	0.31	-67.88	0.23
145	-70.50	0.26	-71.62	0.21
155	-74.08	0.22	-74.80	0.18
165	-77.04	0.19	-77.49	0.17
175	-79.47	0.16	-79.77	0.15
185	-81.50	0.15	-81.71	0.15
195	-83.22	0.16	-83.37	0.16
200	-84.00	0.18	-84.11	0.18

Used equipment: HP 4278A Capacitance meter and Delta 9023 environmental chamber.

Measured uncertainty: C, DF  $\pm 0.25\%$ .

Room temperature: 19.2°C. Relative humidity: 49.2%.

Page 8 of 16



Page **9** of **16** 

# **Test #5: INSULATION RESISTANCE**

(@ 1000V, RT and 125°C)

Electrical Parameters	CS-18-13-4 (#L-3H)	
	Room Temperature	
IR, Ω	9.23*1012	
ρ, <b>Ω</b> *m	$4.19*10^{11}$	
R*C, MΩ*μF	28908.0	
	125°C	
IR, Ω	$2.05*10^{12}$	
ρ, <b>Ω</b> *m	$9.31*10^{10}$	
R*C, MΩ*μF	2569.6	

Used equipment: Beckman Megaohmmeter and Delta 9023 environmental chamber.

Measured uncertainty: IR  $\pm 0.25\%$ .

Room temperature: 19.2°C. Relative humidity: 49.2%.

Page 10 of 16

# **Test #6: Highly Accelerated Life Test**

(@ 1000V, 180°C, 100h)

	CS-18-13-4
Time, h	(#L-3H)
	$\operatorname{IR},\Omega$
2	1.6*1011
12	$8.9*10^{10}$
24	$9.4*10^{10}$
36	$9.6*10^{10}$
48	$9.9*10^{10}$
60	$9.9*10^{10}$
72	1.1*10 <sup>11</sup>
84	1.3*10 <sup>11</sup>
96	$1.4*10^{11}$
100	1.5*1011

Used equipment: Custom made HT-HALT system.

Measured uncertainty: IR  $\pm 0.25\%$ .

Room temperature: 19.2°C. Relative humidity: 49.2%.

Page 11 of 16

# Test #7: AC and DC Dielectric Breakdown Strength

(@ Room temperature)

Electrical Parameters	CS-18-13-4 (#L-3H)
<u> </u>	DC Dielectric Breakdown
Ultimate Dielectric Breakdown, Vdc	>6000
Dielectric Breakdown Strength, Vdc/µm	>11.0
	AC Dielectric Breakdown
Ultimate Dielectric Breakdown, Vac	3239
Dielectric Breakdown Strength, Vac/μm	5.9


Used equipment: Chroma Sentry Plus HiPot tester 19073.

Measured uncertainty  $\pm 0.25\%$ .

Room temperature: 19.2°C. Relative humidity: 49.2%.


Page 12 of 16

**Test #8:** Cross-section and optical/SEM microstructure evaluation.



15 Print Works Drive Adams, MA 01220

Page **13** of **16** 



15 Print Works Drive Adams, MA 01220

Page **14** of **16** 

# **Test Methods**

The below methods were used to perform the tests.

#### General

All measurement equipment was powered up at least 30 minutes prior to testing and allowed to reach a stable temperature.

#### Test #1: Capacitance & Dissipation Factor vs. Frequency (20Hz – 2MHz)

Electrical parameters at variable frequencies were measured using Keysight E4980A Precision LCR Meter. The measurements were performed at room temperature at 1Vrms voltage condition. Open/short correction was performed prior to measurements in order to compensate for stray admittance and residual impedance of the probe. The measurements were performed one time per sample. Dielectric constant of the densified ceramic and polymer-ceramic disks was estimated by using parallel plate capacitor model. The thickness of the disks and the area of sputtered gold electrodes were measured using a precision micrometer, while the capacitance was taken from measurements of the capacitance at variable frequencies at room temperature.

# Test #2: Capacitance & Dissipation Factor vs. dc-bias (up to 1000V)

Electrical parameters at variable dc-biases were measured using Keysight E4980A Precision LCR Meter coupled with Acopian High Voltage Power Supply and ART ASY0360 HV Bias Module. The measurements were performed at room temperature at 1Vrms voltage condition. Open/short correction was performed prior to measurements in order to compensate for stray admittance and residual impedance of the probe. The measurements were performed one time per sample.

### **Test #3: Temperature Coefficient of Capacitance**

Temperature coefficient of capacitance was measured using HP 4278A 1kHz/1MHz Capacitance Meter coupled with Rokem Scanner and Delta 9023 Environmental Chamber. The measurements were performed in the temperature range from -55°C to 200°C. Three minutes were allowed for temperature stabilization prior to measurements of capacitance and dissipation factor at each temperature steps. Open/short correction was performed prior to measurements in order to compensate for stray admittance and residual impedance of the scanner. The measurements were performed one time per sample.

Page 15 of 16

### Test #4: Temperature Coefficient of Capacitance at dc-bias

Temperature coefficient of capacitance at dc-bias was measured using HP 4278A 1kHz/1MHz Capacitance Meter coupled with Rokem Scanner, Sorensen DLM 300-2 Programmable dc Power Supply, ART ASY0360 HV Bias Module, and Delta 9023 Environmental Chamber. The measurements were performed in the temperature range from -55°C to 200°C. Three minutes were allowed for temperature stabilization prior to measurements of capacitance and dissipation factor at each temperature steps with and without 300V dc-bias. Open/short correction was performed prior to measurements in order to compensate for stray admittance and residual impedance of the scanner. The measurements were performed one time per sample.

#### **Test #5: Insulation Resistance**

Insulation resistance at 1000V dc-bias was measured using Beckman Megaohmmeter coupled with Delta 9023 Environmental Chamber. The measurements were performed at room temperature and at 125°C. 10 minutes were allowed for the temperature stabilization inside the chamber before each measurements. The insulation resistance was recorded after 2 minutes of dc-bias being applied. The measurements were performed one time per sample.

# **Test #6: Highly Accelerated Life Test (HALT)**

Highly Accelerated Life Test (HALT) was performed at 180°C under the applied 1000V dc-bias using a custom made high temperature HALT system consisting of Agilent 34972A LXI Data Acquisition / Switch Unit, Acopian High Voltage Power Supply, and Across Environmental Chamber. The insulation resistance of the samples was recorded every 30 minutes for the duration of 100 hours. The measurements were performed one time per sample.

# Test #7: AC and DC Dielectric Breakdown Strength

AC and DC dielectric breakdown strength measurements at room temperature were performed using Chroma Sentry Plus HiPot tester 19073. The ultimate dielectric breakdown both for AC and DC conditions was recorded during the voltage ramp up with the constant rate of 100V/sec. The samples were coated with a silicon oil to prevent surface arcing. The measurements were performed one time per sample.

Page 16 of 16

### Test #8: Cross-section and optical/SEM microstructure evaluation

Microstructural evaluation of the samples were performed using both optical, Unitron TMS-3906, and scanning electron, ISI-100B, microscopes. The ceramic samples were cross-sectioned and polished down to 1 micron alumina powder finish. Both bright field and dark field illumination was used in the optical microscope to reveal different features of the samples' microstructure.

**<u>Affirmation:</u>** I certify the above to be true and correct and to have witnessed the testing as described

Anton Polotai, Senior Scientist

Cc: RM, SM, JW

**NOTICE:** MRA Laboratories, Inc. strives to maintain a high standard in the conduct and reporting of its testing and professional services. Best efforts are made to assure equipment is properly maintained and calibrated and that correct procedures are followed. All results are discussed and reviewed by the project lead and at least one other qualified technical person prior to reporting.

Test results are considered advisory and/or experimental in nature. Therefore, neither MRA, nor its employees, assume any obligation or liability for damages, including, but not limited to consequential damages, arising out of or in conjunction with the use, or inability to use, the resulting information. Questionable results should be called to the attention of MRA as soon as possible.